

CERTIFICATE OF AUTOMATIC TANK GAUGE FUNCTIONALITY TESTING

Fuller Installations Inc
9 Louis St.
North Haven CT 06473

Service Order#: *Fwo# 39201*

Test Date: *6/28/03*

Customer PO#:

CUSTOMER:
Fairfield Police

LOCATION: *100 reef rd,
Fairfield, CT*

ATG CERTIFICATION

Type of Monitoring system:

TIS-300

Serial #: *312100171605003*

Operational

Software Version #

Positive shut-down:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A
Functioning audible & visual alarms:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A
Inventory Probes functioning properly:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A
Sensors functioning properly:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A
Dedicated circuit breaker properly marked:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A
External overfill alarm:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A
System Certified Per Manufacturer's Specifications:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	

Equipment Profile

Tank # 1: *Mid-grade*

Model / Form #

- Annular Sensor
- Inventory Probe
- STP Sensor
- Pipe Sensor
- Electronic LLD
- Other
- N/A

Tank # 2: *Rel oil*

Model / Form #

- Annular Sensor
- Inventory Probe
- STP Sensor
- Pipe Sensor
- Electronic LLD
- Other
- N/A

Tank # 3:

Model / Form #

- Annular Sensor
- Inventory Probe
- STP Sensor
- Pipe Sensor
- Electronic LLD
- Other
- N/A

Tank # 4:

Model / Form #

- Annular Sensor
- Inventory Probe
- STP Sensor
- Pipe Sensor
- Electronic LLD
- Other
- N/A

Tank # 5:

Model / Form #

- Annular Sensor
- Inventory Probe
- STP Sensor
- Pipe Sensor
- Electronic LLD
- Other
- N/A

Tank # 6:

Model / Form #

- Annular Sensor
- Inventory Probe
- STP Sensor
- Pipe Sensor
- Electronic LLD
- Other
- N/A

Comments:

All test OK

Certification Technician:

[Signature]